



www.ctllabs.in  
www.foodenvironmenttesting.com

CIN : U74999TN2008PTC067568

**TEST REPORT**

Report Number and date	CTL/CH/0272/2016-17 & 23.06.2016		
Sample Number	0272/16-17		
Customer Name & Address	M/s.Farm Totable Food Logic India Pvt. Ltd.,		
	F1, Rand Enclave, 1, Guindy Engineers Colony, Kokilambal Nagar, Chennai - 600 097.		
<b>SAMPLE DETAILS</b>			
Sample Description By Customer	RO Water		
Sampling Date	NA	Sampled By	Customer
Sampling Location	NA	Sampling Method	NA
Quantity Received	2 Litres	Lot / Batch No	Not Available
Additional Information By Customer	Sample Mark: Farm Totable		
Date of Receipt	17.06.2016	Sample Condition	Good & Received in Plastic Container
Analysis Starting Date	18.06.2016	Analysis Completion Date	22.06.2016

**Test Results:**

The above sample tested as received, and results are as follows:

S. NO	PARAMETERS	METHOD	UNITS	RESULTS	LIMITS*
1	Appearance	Physical Observation	-	Clear Liquid	-
2	Colour	IS 3025 (Part 4)-1983 (R.2006)	HU	2	Max.5.0
3	pH @ 25°C	IS 3025 (Part 11)-1983 (R.2006)	-	6.7	6.5 to 8.5
4	Odour	IS 3025 (Part 5)-1983 (R.2006)	-	Unobjectionable	Unobjectionable
5	Turbidity	IS 3025 (Part 10)-1984 (R.2006)	NTU	< 1	Max.1.0
6	Total Hardness as CaCO <sub>3</sub>	IS 3025 (Part 21)-1983 (R.2006)	mg/l	7	Max.200
7	Calcium as Ca	IS 3025 (Part 40)-1991 (R.2009)	mg/l	3	Max.75
8	Magnesium as Mg	IS 3025 (Part 46)-1994 (R.2003)	mg/l	< 1	Max.30
9	p-Alkalinity as CaCO <sub>3</sub>	IS 3025 (Part 23)-1986 (R.2009)	mg/l	Nil	-
10	Total Alkalinity as CaCO <sub>3</sub>	IS 3025 (Part 23)-1986 (R.2009)	mg/l	18	Max.200
11	Chloride as Cl <sup>-</sup>	IS 3025 (Part 32)-1988 (R.2009)	mg/l	28	Max.250
12	Sulphate as SO <sub>4</sub>	IS 3025 (Part 24)-1986 (R.2009)	mg/l	< 2	Max.200
13	Total Dissolved Solids	IS 3025 (Part 16)-1984 (R.2006)	mg/l	58	Max.500
14	Iron as Fe	IS 3025 (Part 53)-2009	mg/l	BDL (DL:0.01)	Max.0.3
15	Silica as SiO <sub>2</sub>	IS 3025 (Part 35)-1988 (R.2003)	mg/l	2	-
16	Carbonate Hardness	IS 3025 (Part 21)-1983 (R.2006)	mg/l	7	-
17	Non Carbonate Hardness	IS 3025 (Part 21)-1983 (R.2006)	mg/l	Nil	-

BDL - Below Detection Limit; DL - Detection Limit; Max. - Maximum; NA - Not Applicable

\*As per Drinking Water Specification IS 10500:2012

Verified by

For Chennai Testing Laboratory Pvt Ltd

Authorised Signatory  
  
**A. RAJKUMAR**  
Technical Manager

Page 1 of 2



CIN : U74999TN2008PTC067568

www.ctllabs.in  
www.foodenvironmenttesting.com

**TEST REPORT**

Report Number and date	CTL/CH/0272/2016-17 & 23.06.2016		
Sample Number	0272/16-17		
Customer Name & Address	M/s.Farm Totable Food Logic India Pvt. Ltd.,		
	F1, Rand Enclave, 1, Guindy Engineers Colony, Kokilambal Nagar, Chennai - 600 097.		
<b>SAMPLE DETAILS</b>			
Sample Description By Customer	RO Water		
Sampling Date	NA	Sampled By	Customer
Sampling Location	NA	Sampling Method	NA
Quantity Received	2 Litres	Lot / Batch No	Not Available
Additional Information By Customer	Sample Mark: Farm Totable		
Date of Receipt	17.06.2016	Sample Condition	Good & Received in Plastic Container
Analysis Starting Date	17.06.2016	Analysis Completion Date	22.06.2016

**Test Results:**

The above sample tested as received, and results are as follows:


S. NO	PARAMETERS	METHOD	UNITS	RESULTS	LIMITS*
1	Total Coliform	IS:1622 : 1981 (R.2009)	MPN/100ml	< 2	Shall not be detectable in any 100 ml of sample
2	<i>E.coli</i>	IS:1622 : 1981 (R.2009)	MPN/100ml	< 2	

Note: < 2 can be considered as Absent

\*As per Drinking Water Specification IS 10500:2012

REMARKS: The Sample meets the requirement of IS 10500:2012 with respect to the parameters tested.

\*\*\*END OF REPORT\*\*\*

Verified by 

For Chennai Testing Laboratory Pvt Ltd  
  
Authorised Signatory  
**N. RAJENDRAKUMAR**  
Technical Manager - Micro

Page 2 of 2